





TECHNICAL BID EVALUATION REPORT

Name of Procuring Agency			National Institute of Banking and Finance Pakistan, Islamabad											
Method of procurement			PPRA Rule 36 b (Single Stage-Two Envelop Procedure)											
Title of Procurement			Supply & Installation of Fire Alarm System in Hostel Block at NIBAF Islamabad											
PPRA Ref. No. (TSE)			TS551408E											
Date & Time of Bid Closing			12-12-2024 till 03:00 PM											
Date & Time of Bid Opening			12-12-2024 at 03:30 PM											
No. of Tenders issued to bidders			Tender through EPADS											
EVALUATION CRITERIA			SUBMISSION/COMPLIANCE BY THE BIDDERS											
			M/s Aljibra Technologies		M/s Firesafety Trading (Pvt) Ltd.		M/s ADAMS FIRE TECH PVT LTD		M/s Imcoats (Pvt) Ltd		M/s AYJ Solutions		M/s Haseen Habib Trading (Pvt) Ltd	
Sr No	Eligibility / Qualification Criteria	Annexure / Page	Submitted	Remarks	Submitted	Remarks	Submitted	Remarks	Submitted	Remarks	Submitted	Remarks	Submitted	Remarks
1	Conditional / Un-conditional Bid is un-conditional, conditional bids shall be rejected.		As per bid document	Ok	As per bid document	Ok	As per bid document	Ok	As per bid document	Ok	As per bid document	Ok	Company Letter	Ok
2	Bid Security Bid Security is required as per Clause ITB-18.1. Bid Security in Original is to be attached with Technical Proposal.		Received	Ok	Received	Ok	Received	Ok	Received	Ok	Received	Ok	Received	Ok
3	Income Tax and General Sales Tax Bidder must be registered with FBR in Income Tax and General Sales Tax and must active taxpayer as per Federal Board of Revenue (FBR's) revenue Data base i.e Active Tax Payer List.		Not Provided	Not ok	Registered	Ok	Registered	Ok	Registered	Ok	Registered	Ok	Registered	Ok
4	Revenue Authority Registration The Bidder should also be registered with relevant / concerned Revenue Authority. If not registered, the 100% tax shall be deducted at source as per applicable law and credited to relevant account.		Not Provided	Not ok	Registered	Ok	Registered	Ok	Registered	Ok	Registered	Ok	Registered	Ok
5	Company Registration i. Name of Company ii. Company Legal Status: (Tick Anyone and provide relevant documents) 1. In case of Individual / Sole Proprietor a) Copy of CNIC b) Affidavit that firm is individual / Sole proprietor 2. In case of Associated of Persons (AOP) a) Partnership Deed b) No. of Partners along with CNIC 3. In case of (Pvt.) limited a) Copy of Article of Association / Memorandum b) Form 29, Form A and Nos of Directors along with copy of CNIC iii. Contact details, Telephone, Mobile No., Fax numbers(if any), email address (if any) Postal Address		Not Provided	Not ok	(Pvt.) limited	Ok	(Pvt.) limited	Ok	(Pvt.) limited	Ok	Received	Ok	(Pvt.) limited	Ok
6	Undertaking (As per Form – T4 attached) The bidder is required to submit an undertaking on stamp paper of Rs.100/- as per format provided in Form – T4.		Not Provided	Not ok	Received	Ok	Received	Ok	Received	Ok	Received	Ok	Received	Ok
7	Valid registration with Pakistan Engineering Council at least in Category C-6 or above with specialization category ME02 (Fire Prevention and Protection System).		Not Provided	Not ok	Valid	Ok	Valid	Ok	Valid	Ok	Expired	Not Ok	Valid	Ok
8	Minimum two (2) works of supply and Installation of fire alarm system of cost Rs. 3 Million or more each, executed during last 5 (five) years (Work order/ completion certificates to be attached).		Not Provided	Not ok	Submitted	Ok	Submitted	Ok	Submitted	Ok	Submitted	Ok	Submitted	Ok
9	Financial Capability/Liquid Assets Available Financial Capability/Liquid Assets of (Rs. 01Million) or above. a. Bank statement be submitted as evidence showing required balance at any one instant in the statement of last three months prior to publication of tender notice. b. Available Bank Credit Line facility or c. Liquid Assets		Not Provided	Not ok	Submitted	Ok	Submitted	Ok	Submitted	Ok	Submitted	Ok	Submitted	Ok
10	Acceptance of the Proposed Work Program as given in document or Work Program proposed by the bidder with overall project duration as mentioned in the contract data.		Not Provided	Not ok	Submitted	Ok	Submitted	Ok	Submitted	Ok	Submitted	Ok	Submitted	Ok
11	Technical Compliance with Annexure – A The offered equipment must technically comply with the minimum technical specification listed in Annexure – A of the Bid. The Bidder shall submit technical brochures and component satisfying that the offered equipment complies with the standard listed in Annexure-A.		Compliant	Ok	Compliant	Ok	Compliant	Ok	Non Compliant	Not Ok	Compliant	Ok	Compliant	Ok
In view of the Bidder's Eligibility / Qualification Criteria, the bid has been found:			Non Responsive		Responsive		Responsive		Non Responsive		Non Responsive		Responsive	
														
			Assistant Executive Engineer		Deputy Director		Joint Director							

Title of Procurement		Supply & Installation of Fire Alarm System in Hostel Block at NIBAF Islamabad						
PPRA Ref. No. (TSE)		TS551408E						
Technical Compliance Standards								
S.No	Item Description	Requirement	Compliance Status of the Bidders					
			M/s Aljibra Technologies	M/s Firesafety Trading (Pvt) Ltd.	M/s ADAMS FIRE TECH PVT LTD	M/s Imcots (Pvt) Ltd	M/s AYJ Solutions	M/s Haseen Habib Trading (Pvt) Ltd
1	4-loop analogue addressable fire alarm control panel	with 4 Notification Appliance Circuits (expandable upto 4 loops), with additional power supplies for sounders as required etc Temperature: 0 to 49°C (32 to 120°F) Relative humidity: 0 to 93% noncondensing, having UL standard Approval or FM Approval	Maple Armor, UL 864, FW106 (R)	Velocity, UL 864, VL-MMP	Carrier, UL 864, GST-M200	Ceasefire CFI5109 Italia,	EDWARDS, UL, iO64, iO1000	EDWARDS, UL, iO64, iO1000
2	Analogue addressable point type photoelectric-type smoke detector	Operating environment 32 to 100°F (0 to 38°C), 0 to 93% RH, noncondensing, having UL standard Approval or FM Approval	Maple Armor, UL, FW511	Velocity, UL, VDOT-PY	Carrier, UL, DI-M9102	Ceasefire CFI5131 Italia,	EDWARDS, UL, SIGA-OSD	EDWARDS, UL, SIGA-OSD
3	Analogue addressable manual pull station	Operating environment 32 to 100°F (0 to 38°C), 0 to 93% RH, noncondensing, having UL standard Approval or FM Approval	Maple Armor, UL, FW527	Velocity, UL, VDOT-42SK	Carrier, UL, DI-M9204	Ceasefire CFISB5214 Italia,	EST, UL SIGA 270	EST, UL SIGI-271
4	Class A wiring of fire alarm system Initiating components	shielded fire resistant 30 minutes (PH30) cable	SHENZHEN LILUTONG TECHNOLOGY INDUSTRY CO LTD, UL	Shield, LPCB, PH30	2M Kablo, LPCB, PH 30	No Data	2M Kablo, LPCB, PH 30	Pramcro, LPCB, PH120
5	Class B wiring of fire alarm system notification components	shielded fire resistant 30 minutes (PH30) cable	SHENZHEN LILUTONG TECHNOLOGY INDUSTRY CO LTD, UL	Shield, LPCB, PH30	2M Kablo, LPCB, PH 30	No Data	2M Kablo, LPCB, PH 30	Pramcro, LPCB, PH120
Technical Compliance with Annexure – A			Compliant	Compliant	Compliant	Non Compliant	Compliant	Compliant
 Assistant Executive Engineer  Deputy Director  Joint Director								